

# ABSICHERUNG HALLENTIEFSTRAHLER

	Absicherung Hallentiefstrahler		Kontaktbelastbarkeit	
	Stück max.		z. B. Relaiskontakten	
	B16	C16		
HTS100				
<b>MGL3543</b>	4	8	60A	550µS
<b>MGL3544</b>	4	8	60A	550µS
<b>MGL3545</b>	4	8	60A	550µS
<b>MGL3546</b>	4	8	60A	550µS
<b>MGL3547</b>	4	8	60A	550µS
<b>MGL3548</b>	4	8	60A	550µS
HTS150				
<b>MGL3549</b>	4	7	65A	550µS
<b>MGL3550</b>	4	7	65A	550µS
<b>MGL3551</b>	4	7	65A	550µS
<b>MGL3552</b>	4	7	65A	550µS
<b>MGL3553</b>	4	7	65A	550µS
<b>MGL3554</b>	4	7	65A	550µS
HTS200				
<b>MGL3555</b>	2	4	85A	600µS
<b>MGL3556</b>	2	4	85A	600µS
<b>MGL3557</b>	2	4	85A	600µS
<b>MGL3558</b>	2	4	85A	600µS
<b>MGL3559</b>	2	4	85A	600µS
<b>MGL3560</b>	2	4	85A	600µS
HTS240				
<b>MGL3561</b>	2	3	75A	680µS
<b>MGL3562</b>	2	3	75A	680µS
<b>MGL3563</b>	2	3	75A	680µS
<b>MGL3564</b>	2	3	75A	680µS
<b>MGL3565</b>	2	3	75A	680µS
<b>MGL3566</b>	2	3	75A	680µS

